

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 655/DLWQ7ML/UJS/2025-26

Dated: 02-06-2025

It is certified that an inspection team headed by Dr. Vikash Kandari, chief chemist

(Name of Officers with designation) from District Lab., Dehradun PHED

inspected the Gyan Einstein International School, Shisham bada, Dehradun

(Name & Address of the school) on 29-05-25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 655/UJS/DLWQ7ML/2526 dated 02-06-2025

of District Lab., Dehradun..... (PHED Lab) certified that the

Gyan Einstein International School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till As per rule (01-06-2026)

Authorized Signature

DLWQ7ML

Uttarakhand Jal Sansthan

Signature with Seal: 

Name : Dr. Vikash Kandari

Designation : Chief Chemist

Name & Address of the Office / Department : UJS, Dehradun

To, Gyan Einstein International School, Shisham bada, Parwan Road, Dehradun  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



**District Level Water Quality Testing And Monitoring Laboratory**  
**Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun**

TC-13625

**TEST REPORT**

<b>Name and Address of Organization/ Customer</b>	Gyan Einstein International School, Shishambara, Parwal Road, Shimla Bypass Road Dehradun		
<b>Test Report ID</b>	655/UJS/DLWQTM/2025-26	<b>Reporting Date</b>	02/06/2025
<b>ULR No.</b>	TC1365240000000000167F	<b>Sample Location</b>	Shishambara, Parwal Road, Shimla Bypass Road Dehradun
<b>Product Description</b>	Drinking Water	<b>Sample Collected by</b>	Customer
<b>Reference Sample Identification</b>	DLWQTM/UJS/2025-563		
<b>Date of Start of Analysis:</b>	29/05/2025		
<b>Date of End of Analysis:</b>	02/06/2025		
<b>Date and Time of Sample Received:</b>	29/05/2025 & 2:36 PM		

SN	Parameters	Test Method	Results	Acceptable Limit As Per (IS 10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1.	pH at 25°C	IS 3025 (Part 11) 2022,	6.96	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C mg/L, Max	IS 3025 (Part 16) 2023,	357	500	2000
3.	Turbidity, NTU, Max	IS 3025 (Part 10) 2023,	0.98	1	5
4.	Total Alkalinity (as CaCO <sub>3</sub> ), mg/L, Max	IS 3025 (Part 23) 2023,	256	200	600
5.	Total Hardness (as CaCO <sub>3</sub> ), mg/L, Max	IS 3025 (Part 21) 2009,	280	200	600
6.	Calcium as Ca, mg/L, Max	IS 3025 (Part 40) 2019,	55.2	75	200
7.	Chloride, mg/L, Max	IS 3025 (Part 32) 2019,	22.48	250	1000
8.	Magnesium as Mg, mg/L, Max	ALPHA 24 <sup>th</sup> Ed-3500-Mg Method B:2023 (Calculation Method)	34.50	30	100
9.	Colour, Hazen, Max	IS 3025 (Part 4): 2021,	Less than 01	5	15
10.	Odour	IS 3025 (Part 5): 2018,	Agreeable	Aggregable	Aggregable

Note :-

1. The result listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received.
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer.

\*\*\*\*End of Report\*\*\*\*

**Review and Authorized By**

  
**Authorized Signature**  
(Dr. Deepak Kumar, 02/06/2025)  
**Deepak Kumar**  
Technical Manager, Lab  
**Uttarakhand Jal Sansthan**